

# Citation Frequency Report

Selection Criteria

**Begin Year:** 2007  
**End Year:** 2007  
**Display Options** Display top 25 tags

**Provider and**

**Supplier** Intermediate Care Facility-Mentally Retarded

**Type(s):**

**State:** Idaho

**Survey Focus:** Life Safety

**Year Type:** Calendar Year **Year:** 2007 **Month:** Full Year

**Totals represent the # of providers and surveys that meet the selection criteria specified above.**

Idaho Active Providers = 65		Total Number of Surveys = 77			
Tag #	Tag Description	# Citations	% Providers Cited	% Surveys Cited	Rank
K 150	Furnishing and decorations	15	23.10%	19.50%	1
K 046	Emergency lighting	14	21.50%	18.20%	2
K 056	Automatic sprinkler system	10	15.40%	13.00%	3
K 029	Hazardous areas - separation	9	12.30%	11.70%	4
K 152	Evacuation drills	6	7.70%	7.80%	5
K 154	Automatic sprinkler system	5	1.50%	6.50%	6
K 155	Fire alarm system outage requirements	5	1.50%	6.50%	6
K 053	Automatic smoke detection system	2	3.10%	2.60%	7
K 011	Common wall	2	3.10%	2.60%	7
K 051	Fire alarm system	2	1.50%	2.60%	7
K 130	Other	2	3.10%	2.60%	7
K 012	Construction type	1	1.50%	1.30%	8
K 018	Corridor doors	1	1.50%	1.30%	8

Tag #	Tag Description	# Citations	% Providers Cited	% Surveys Cited	Rank
K 144	Generators inspected/tested	1	1.50%	1.30%	8
K 014	Interior finish - corridor	1	1.50%	1.30%	8
K 119	Other hazardous areas	1	1.50%	1.30%	8
K 043	Patient room locks	1	1.50%	1.30%	8