



C.L. "BUTCH" OTTER -- Governor  
RICHARD M. ARMSTRONG -- Director

IDAHO DEPARTMENT OF  
HEALTH & WELFARE

DEBBY RANSOM, R.N., R.H.I.T -- Chief  
BUREAU OF FACILITY STANDARDS  
3232 Elder Street  
P.O. Box 83720  
Boise, Idaho 83720-0009  
PHONE: (208) 334-6626  
FAX: (208) 364-1888  
E-mail: [fsb@dhw.idaho.gov](mailto:fsb@dhw.idaho.gov)

February 11, 2015

Bridger Fly, Administrator  
Communicare, Inc #2 Boone  
40 West Franklin Road, Suite F  
Meridian, ID 83642

RE: Communicare, Inc #2 Boone, Provider #13G009

Dear Mr. Fly:

This is to advise you of the findings of the Medicaid/Licensure Fire Life Safety Survey, which was concluded at Communicare, Inc #2 Boone, on February 2, 2015.

Enclosed is your copy of a Statement of Deficiencies/Plan of Correction, form CMS-2567, which states that no Medicaid deficiencies were noted at the time of the survey. Also, enclosed is a similar form stating that no State licensure deficiencies were noted at the time of the survey.

Thank you for the courtesies extended to our staff during our visit. If you have any questions, please call our office at (208) 334-6626.

Sincerely,

MARK P. GRIMES  
Supervisor  
Facility Fire Safety and Construction Program

MPG/lj

Enclosure

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

Printed: 02/09/2015  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>13G009</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02</b> - ENTIRE STRUCTURE  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>02/02/2015</b>
NAME OF PROVIDER OR SUPPLIER <b>COMMUNICARE, INC #2 BOONE</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>1210 W BOONE ST NAMPA, ID 83651</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p><b>INITIAL COMMENTS</b></p> <p>The facility is a one story Type V(000) structure that was built in 1980. The facility is fully sprinklered and is licensed for 8 beds. The facility was surveyed in accordance with applicable fire/life safety requirements set forth in the Life Safety Code, 2000 edition, Chapter 33, Existing Residential Board and Care Occupancy, Impractical Evacuation Capability and 42 CFR 483.470.</p> <p>The facility was found to be in substantial compliance during the fire/life safety survey conducted on February 2, 2015.</p> <p>The annual life safety code survey was conducted by:</p> <p>Nathan Elkins Health Facility Surveyor Fire Life Safety &amp; Construction Program</p>	K 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>13G009</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>02 - ENTIRE STRUCTURE</b> B. WING _____	(X3) DATE SURVEY COMPLETED  <b>02/02/2015</b>
NAME OF PROVIDER OR SUPPLIER <b>COMMUNICARE, INC #2 BOONE</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>1210 W BOONE ST NAMPA, ID 83651</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 000	<p>16.03.11 Initial Comments</p> <p>The facility is a one story Type V(000) structure that was built in 1980. The facility is fully sprinklered and is licensed for 8 beds. The facility was surveyed in accordance with applicable fire/life safety requirements set forth in the Life Safety Code, 2000 edition, Chapter 33, Existing Residential Board and Care Occupancy, Impractical Evacuation Capability and IDAPA 16.03.11 Intermediate Care Facilities for People with Intellectual Disabilities.</p> <p>The facility was found to be in substantial compliance during the fire/life safety survey conducted on February 2, 2015.</p> <p>The annual life safety code survey was conducted by:</p> <p>Nathan Elkins Health Facility Surveyor Fire Life Safety &amp; Construction Program</p>	M 000		

If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE