



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T. – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

February 26, 2015

Dawn Brotherson, Administrator
Apple Valley Residential Care
715 North Butte Avenue
Emmett, ID 83617

License #: RC-445

Dear Ms. Brotherson:

On February 17, 2015, a Fire Life Safety Survey was conducted at Apple Valley Residential Care. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level(s):

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Nathan Elkins, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626.

Sincerely,

NATHAN ELKINS
Health Facility Surveyor
Facility Fire Safety & Construction Program

NE/lj



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER, Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T. – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

February 23, 2015

Dawn Brotherson, Administrator
Apple Valley Residential Care
715 North Butte Avenue
Emmett, ID 83617

Dear Ms. Brotherson:

On February 17, 2015, a Fire Life Safety Survey was conducted at Apple Valley Residential Care. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by March 19, 2015.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

MARK P. GRIMES, Supervisor
Facility Fire Safety & Construction Program

MPG/lj
Enclosure

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13R445	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 - ENTIRE BUILDING B. WING _____	(X3) DATE SURVEY COMPLETED 02/17/2015
--	--	--	--

NAME OF PROVIDER OR SUPPLIER APPLE VALLEY RESIDENTIAL CARE	STREET ADDRESS, CITY, STATE, ZIP CODE 715 NORTH BUTTE AVENUE EMMETT, ID 83617
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

R 000	<p>Initial Comments</p> <p>The facility was found to be in substantial compliance with the life safety code requirements of the Rules for Residential or Assisted Living Facilities in Idaho. No core deficiencies were cited during the standard life safety code survey conducted on February 17, 2015.</p> <p>The surveyor conducting the survey was:</p> <p>Nathan Elkins Health Facility Surveyor Fire Life Safety & Construction</p>	R 000		
-------	--	-------	--	--

Bureau of Facility Standards
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE _____ TITLE _____ (X6) DATE _____

