



IDAHO DEPARTMENT OF
HEALTH & WELFARE

G.L. 'BUTCH' OTTER – Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T. – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

June 18, 2015

Mark Phelan, Administrator
Park Center Assisted Living
1212 Longmont Avenue
Boise, ID 83706

License #: RC-810

Dear Mr. Phelan:

On May 13, 2015, a Fire Life Safety Survey was conducted at Park Center Assisted Living. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level:

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Nathan Elkins, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626.

Sincerely,

NATHAN ELKINS
Health Facility Surveyor
Facility Fire Safety & Construction Program

NE/lj



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER, Governor
RICHARD M. ARMSTRONG -- Director

DEBBY RANSOM, R.N., R.H.I.T. -- Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

May 22, 2015

Mark Phelan, Administrator
Park Center Assisted Living
1212 Longmont Avenue
Boise, ID 83706

Dear Mr. Phelan:

On May 13, 2015, a Fire Life Safety Survey was conducted at Park Center Assisted Living. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by June 12, 2015.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

A handwritten signature in black ink, appearing to read "Mark P. Grimes", followed by a long horizontal line extending to the right.

MARK P. GRIMES, Supervisor
Facility Fire Safety & Construction Program

MPG/lj
Enclosure

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13R810	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 - BUILDING 1 B. WING _____	(X3) DATE SURVEY COMPLETED 05/13/2015
--	---	--	---

NAME OF PROVIDER OR SUPPLIER PARK CENTER ASSISTED LIVING	STREET ADDRESS, CITY, STATE, ZIP CODE 1212 LONGMONT AVENUE BOISE, ID 83706
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

R 000	<p>Initial Comments</p> <p>The facility was found to be in substantial compliance with the life safety code requirements of the Rules for Residential or Assisted Living Facilities in Idaho. No core deficiencies were cited during the standard life safety code survey conducted on May 13, 2015</p> <p>The survey was conducted by:</p> <p>Nathan Elkins Health Facility Surveyor Facility Fire Safety & Construction</p>	R 000		
-------	--	-------	--	--

Bureau of Facility Standards
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE _____ TITLE _____ (X6) DATE _____



Facility Name <i>Park Center Assisted Living</i>	Physical Address <i>1212 Longmont Ave</i>	Phone Number <i>208-343-0832</i>
Administrator <i>Mark Phelan</i>	City <i>BOISE</i>	ZIP Code <i>83706</i>
Survey Team Leader <i>Nathan Elkins</i>	Survey Type <i>Fire Life Safety</i>	Survey Date <i>5-13-15</i>

NON-CORE ISSUES

ITEM #	RULE #	DESCRIPTION	DATE RESOLVED
<i>1</i>	<i>750.05 415.04</i>	<i>The facility is not maintaining the fire alarm smoke detection system service & testing on file in the facility</i>	<i>5-14-15</i>
<i>2</i>	<i>750.06 415.05</i>	<i>The facility is not maintaining the Automatic Fire extinguishing System service & testing on file in the facility</i>	<i>5-14-15</i>
<i>3</i>	<i>405.03</i>	<i>Unsecured oxygen bottles in Room #5 (5 total) and in Room #6 (2 total) *Item #1 is a repeat write-up from last survey documented 12-6-13*</i>	<i>5-13-15</i>

Response Required Date <i>6-13-15</i>	Signature of Facility Representative <i>Dawley Johnston</i>
--	--