



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

TAMARA PRISOCK – ADMINISTRATOR
DIVISION OF LICENSING & CERTIFICATION
DEBRA RANSOM, R.N., R.H.I.T., Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, ID 83720-0009
PHONE 208-334-6626
FAX 208-364-1888

August 12, 2015

Michelle Mori, Administrator
Pine Brook Assisted Living Center of Idaho Falls
636 East 1st South
Rigby, ID 83442

License #: RC-813

Dear Ms. Mori:

On July 8, 2015, a Fire Life Safety Survey was conducted at Pine Brook Assisted Living of Idaho Falls. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level:

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Sam Burbank, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626.

Sincerely,

SAM BURBANK
Health Facility Surveyor
Facility Fire Safety & Construction Program

SB/lj



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER, Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

July 17, 2015

Michelle Mori, Administrator
Pine Brook Assisted Living Center of Idaho Falls
636 East 1st South
Rigby, ID 83442

Dear Ms. Mori:

On July 8, 2015, a Fire Life Safety Survey was conducted at Pine Brook Assisted Living of Idaho Falls. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by August 8, 2015.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

MARK P. GRIMES, Supervisor
Facility Fire Safety & Construction Program

MPG/lj
Enclosure

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13R813	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 - BUILDING 1 B. WING _____	(X3) DATE SURVEY COMPLETED 07/08/2015
--	---	--	---

NAME OF PROVIDER OR SUPPLIER PINE BROOK ASSISTED LIVING OF IDAHO FAI	STREET ADDRESS, CITY, STATE, ZIP CODE 1140 SCIENCE CENTER DRIVE IDAHO FALLS, ID 83402
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

R 000	<p>Initial Comments</p> <p>The facility was found to be in substantial compliance with the fire and life safety requirements of IDAPA 16.03.22 Residential Care or Assisted Living Facilities in Idaho. No core deficiencies were cited during the standard fire/life safety survey conducted on July 8, 2015.</p> <p>The surveyor conducting the survey was:</p> <p>Sam Burbank Health Facility Surveyor Facility Fire/Life Safety & Construction Program</p>	R 000		
-------	--	-------	--	--

Bureau of Facility Standards
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE _____ TITLE _____ (X6) DATE _____

