



IDAHO DEPARTMENT OF  
HEALTH & WELFARE

C.L. "BUTCH" OTTER -- Governor  
RICHARD M. ARMSTRONG -- Director

TAMARA PRISOCK -- ADMINISTRATOR  
DIVISION OF LICENSING & CERTIFICATION  
DEBRA RANSOM, R.N., R.H.I.T., Chief  
BUREAU OF FACILITY STANDARDS  
3232 Elder Street  
P.O. Box 83720  
Boise, ID 83720-0009  
PHONE 208-334-6626  
FAX 208-364-1888

August 3, 2015

Melinda Widgren, Administrator  
Aspen Springs Assisted Living  
PO Box 1508  
Spirit Lake, ID 83869

License #: RC-906

Dear Ms. Widgren:

On July 23, 2015, a Fire Life Safety Survey was conducted at Aspen Springs Assisted Living. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level:

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Sam Burbank, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626.

Sincerely,

SAM BURBANK  
Health Facility Surveyor  
Facility Fire Safety & Construction Program

SB/lj



IDAHO DEPARTMENT OF  
HEALTH & WELFARE

C.L. "BUTCH" OTTER - Governor  
RICHARD M. ARMSTRONG -- Director

TAMARA PRISOCK-- ADMINISTRATOR  
DIVISION OF LICENSING & CERTIFICATION  
DEBRA RANSOM, R.N.,R.H.I.T., Chief  
BUREAU OF FACILITY STANDARDS  
3232 Eder Street  
P.O. Box 83720  
Boise, ID 83720-0009  
PHONE 208-334-6626  
FAX 208-364-1888

August 3, 2015

Melinda Widgren, Administrator  
Aspen Springs Assisted Living  
PO Box 1508  
Spirit Lake, ID 83869

Dear Ms. Widgren:

On July 23, 2015, a Fire Life Safety Survey was conducted at Aspen Springs Assisted Living. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.


Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by August 24, 2015.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

MARK P. GRIMES, Supervisor  
Facility Fire Safety & Construction Program

MPG/lj  
Enclosure



IDAHO DEPARTMENT OF  

---

HEALTH & WELFARE

C.L. "BUTCH" OTTER – GOVERNOR  
RICHARD M. ARMSTRONG – DIRECTOR

TAMARA PRISOCK – ADMINISTRATOR  
DIVISION OF LICENSING & CERTIFICATION  
JAMIE SIMPSON – PROGRAM SUPERVISOR  
RESIDENTIAL ASSISTED LIVING FACILITIES  
PROGRAM

P.O. Box 83720  
Boise, Idaho 83720-0009  
Email: [raif@dhw.idaho.gov](mailto:raif@dhw.idaho.gov)  
PHONE (208) 364-1962  
FAX (208) 364-1888

**Punch Items**

**Survey Date:** 07/23/2015

16.03.22.405.05.c. Structure, Maintenance, Equipment to Assure Safety.

Wood stoves must have railings or other protection designed to prevent residents from coming into contact with the stove surfaces;

Northwest bedroom (end of hall) missing door latch

