



IDAHO DEPARTMENT OF  
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor  
RICHARD M. ARMSTRONG – Director

TAMARA PRISOCK – ADMINISTRATOR  
DIVISION OF LICENSING & CERTIFICATION  
DEBRA RANSOM, R.N., R.H.I.T., Chief  
BUREAU OF FACILITY STANDARDS  
3232 Elder Street  
P.O. Box 83720  
Boise, ID 83720-0009  
PHONE 208-334-6626  
FAX 208-364-1888

Marilyn Beutlerr, Administrator  
Edgewood Spring Creek Meridian  
PO Box 13238  
Grand Forks ND 58201

License #: RC-1008

Dear Ms. Beutlerr:

On August 19, 2015, a Fire Life Safety Survey was conducted at Edgewood Spring Creek Meridian, LLC. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level(s):

- Non-core issues, which are described on Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted plan of correction and evidence of resolution.

Should you have questions, please contact Sam Burbank, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626.

Sincerely,

Sam Burbank  
Health Facility Surveyor  
Facility Fire Safety & Construction Program

SB/lj



IDAHO DEPARTMENT OF  
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor  
RICHARD M. ARMSTRONG – Director

TAMARA PRISOCK – ADMINISTRATOR  
DIVISION OF LICENSING & CERTIFICATION  
DEBRA RANSOM, R.N., R.H.I.T., Chief  
BUREAU OF FACILITY STANDARDS  
3232 Eider Street  
P.O. Box 83720  
Boise, ID 83720-0009  
PHONE 208-334-6626  
FAX 208-364-1888

August 27, 2015

Marilyn Beutler, Administrator  
Edgewood Spring Creek Meridian  
PO Box 13238  
Grand Forks ND 58201

Dear Ms. Beutler:

On August 19, 2015, a Fire Life Safety Survey was conducted at Edgewood Spring Creek Meridian. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.


Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by September 21, 2015.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

MARK P. GRIMES, Supervisor  
Facility Fire Safety & Construction Program

MPG/lj  
Enclosure



IDAHO DEPARTMENT OF  
HEALTH & WELFARE

C.L. "BUTCH" OTTER – GOVERNOR  
RICHARD M. ARMSTRONG – DIRECTOR

TAMARA PRISOCK – ADMINISTRATOR  
DIVISION OF LICENSING & CERTIFICATION  
JAMIE SIMPSON – PROGRAM SUPERVISOR  
RESIDENTIAL ASSISTED LIVING FACILITIES  
PROGRAM

P.O. Box 83720  
Boise, Idaho 83720-0009  
Email: [ralf@dhw.idaho.gov](mailto:ralf@dhw.idaho.gov)  
PHONE (208) 364-1962  
FAX (208) 364-1888

### Punch Items

Survey Date: 08/19/2015

#### 16.03.22.405.07. Exit Door Locks.

Any locks on exit doors must be single action and easily operable from the inside without the use of keys or any special knowledge. Special locking arrangements as permitted in Chapter 7 of the NFPA, Standard 101, Life Safety Code, 2000 Edition, can be used.

- 1) Padlocks on gates at Memory care not readily identifiable by staff as to which key unlocks which lock - (keyed differently).
- 2) Keys to padlocks locked inside bedroom.
- 3) Deadbolt and padlock installed on Northwest gate preventing immediate egress if both activated.

