



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

TAMARA PRISOCK – ADMINISTRATOR
DIVISION OF LICENSING & CERTIFICATION
DEBRA RANSOM, R.N., R.H.I.T., Chief
BUREAU OF FACILITY STANDARDS
3232 Eder Street
P.O. Box 83720
Boise, ID 83720-0009
PHONE 208-334-6626
FAX 208-364-1888

September 29, 2015

Jenifer Christensen, Administrator
Harmony House II
PO Box 2792
Hayden ID 83835

License #: RC-821

Dear Ms. Christensen:

On August 28, 2015, a Fire Life Safety Survey was conducted at Harmony House Assisted Living II - Harmony House. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level:

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Nathan Elkins, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626.

Sincerely,

Nathan Elkins
Health Facility Surveyor
Facility Fire Safety & Construction Program

NE/lj



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER - Governor
RICHARD M. ARMSTRONG - Director

TAMARA PRISOCK-- ADMINISTRATOR
DIVISION OF LICENSING & CERTIFICATION
DEBRA RANSOM, R.N., R.H.I.T., Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, ID 83720-0009
PHONE 208-334-6626
FAX 208-364-1888

September 3, 2015

Jenifer Christensen, Administrator
Harmony House II
PO Box 2792
Hayden ID 83835

Dear Ms. Christensen:

On August 28, 2015, a Fire Life Safety Survey was conducted at Harmony House Assisted Living II - Harmony House. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by September 28, 2015.

Should you have any questions about our visit, please contact me at (208) 334-6626, option 3.

Sincerely,

MARK P. GRIMES, Supervisor
Facility Fire Safety & Construction Program

MPG/lj
Enclosure

Punch Items

Survey Date: 08/28/2015

16.03.22.415.01. Maintenance of Equipment and Systems.

The facility must assure that all equipment and systems are properly maintained to assure the safety of the residents.

Battery powered Emergency lights located in the back room near the exit were not operational.

