



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

TAMARA PRISOCK – ADMINISTRATOR
DIVISION OF LICENSING & CERTIFICATION
DEBRA RANSOM, R.N., R.H.I.T., Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, ID 83720-0009
PHONE 208-334-6626
FAX 208-364-1888

September 14, 2015

Steve Lish, Administrator
Discovery Care Center
600 Shanafelt Street
Salmon ID 83467

License #: RC-1029

Dear Mr. Lish:

On September 1, 2015, a Fire Life Safety Survey was conducted at Sawtooth Healthcare, Inc., DBA Discovery Care Center. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level:

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Sam Burbank, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626.

Sincerely,

SAM BURBANK
Health Facility Surveyor
Facility Fire Safety & Construction Program

SB/lj



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

TAMARA PRISOCK-- ADMINISTRATOR
DIVISION OF LICENSING & CERTIFICATION
DEBRA RANSOM, R.N., R.H.I.T., Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, ID 83720-0009
PHONE 208-334-6626
FAX 208-364-1888

September 14, 2015

Steve Lish, Administrator
Discovery Care Center
600 Shanafelt Street
Salmon, ID 83467

Dear Mr. Lish:

On September 1, 2015, a Fire Life Safety Survey was conducted at Sawtooth Healthcare, Inc., DBA Discovery Care Center. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by October 1, 2015.

Should you have any questions about our visit, please contact me at (208) 334-6626, option 3.

Sincerely,

A handwritten signature in black ink, appearing to read 'M. Grimes', with a long horizontal flourish extending to the right.

MARK P. GRIMES, Supervisor
Facility Fire Safety & Construction Program

MPG/lj
Enclosure

Punch Items

Survey Date: 09/01/2015

16.03.22.405.05. Structure, Maintenance, Equipment to Assure Safety.

The facility must be structurally sound, maintained, and equipped to assure the safety of residents, personnel, and the public including:

- 1) Entrance door latch stuck closed

- 2) Mechanical/Janitor storage room door self-closure has been removed;
Hazardous Area door will not self-close; (Repeat)

