



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

TAMARA PRISOCK-- ADMINISTRATOR
DIVISION OF LICENSING & CERTIFICATION
DEBRA RANSOM, R.N.,R.H.I.T., Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, ID 83720-0009
PHONE 208-334-6626
FAX 208-364-1888

October 13, 2015

Cheryl Kosankle, Administrator
Pacifica Senior Living Pinehurst
208 South Division Street
Pinehurst ID 83850

License #: RC-1066

Dear Ms. Kosankle:

On September 21, 2015, a Fire Life Safety Survey was conducted at Pacifica Senior Living Pinehurst. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level:

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted plan of correction and evidence of resolution.

Should you have questions, please contact Nathan Elkins, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626.

Sincerely,

NATHAN ELKINS
Health Facility Surveyor
Facility Fire Safety & Construction Program

NE/lj



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER - Governor
RICHARD M. ARMSTRONG - Director

TAMARA PRISOCK - ADMINISTRATOR
DIVISION OF LICENSING & CERTIFICATION
DEBRA RANSOM, R.N., R.H.I.T., Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, ID 83720-0009
PHONE 208-334-6626
FAX 208-364-1888

September 30, 2015

Cheryl Kosankle, Administrator
Pacifica Senior Living Pinehurst
208 South Division Street
Pinehurst, ID 83850

Dear Ms. Kosankle:

On September 21, 2015, a Fire Life Safety Survey was conducted at Pacifica Senior Living Pinehurst. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by October 21, 2015.

Should you have any questions about our visit, please contact me at (208) 334-6626, option 3.

Sincerely,

MARK P. GRIMES, Supervisor
Facility Fire Safety & Construction Program

MPG/lj
Enclosure

Punch Items

Survey Date: 09/21/2015

16.03.22.405.03. Medical Gases.

Handling, use and storage of medical gas must be according to NFPA Standard 99, Standard for Health Care Facilities, 2003 Edition.

Building #1 in Room #12 found an unsecured oxygen bottle on the ground

16.03.22.415.01. Maintenance of Equipment and Systems.

The facility must assure that all equipment and systems are properly maintained to assure the safety of the residents.

Building #2 - Emergency Light system in hallway near room #9 found to be not operational.

16.03.22.405.03. Medical Gases.

Handling, use and storage of medical gas must be according to NFPA Standard 99, Standard for Health Care Facilities, 2003 Edition.

Building #2 Found unsecured oxygen bottle located in shower room.

16.03.22.405.03. Medical Gases.

Handling, use and storage of medical gas must be according to NFPA Standard 99, Standard for Health Care Facilities, 2003 Edition.

Building #2 found oxygen storage located in shower room that did not have signage stating oxygen storage.



Facility Name <i>Pacifica Senior Living - Pinehurst</i>	Physical Address <i>208 S. Division ST</i>	Phone Number <i>208-682-9170</i>
Administrator <i>Cheryl Kosanke</i>	City <i>Pinehurst</i>	ZIP Code <i>83850</i>
Survey Team Leader <i>Nate Elkins</i>	Survey Type <i>FIRE LIFE SAFETY</i>	Survey Date <i>9-21-15</i>

NON-CORE ISSUES

ITEM #	RULE #	DESCRIPTION	DATE RESOLVED	L & C USE
1	405.03	Building #1 - RM 12 found unsecured oxygen bottle on floor	9/23/15	NE
2	415.01	Building #2 - Emergency light not operational in hallway near room 9	9/23/15	NE
3	405.03	Building #2 - unsecured oxygen bottle found in hallway Shower room	9/23/15	NE
4	405.03	Building #2 - No signage showing oxygen storage for Shower room	9/23/15	NE

Response Required Date <i>10-21-15</i>	Signature of Facility Representative <i>Cheryl C. Kosanke</i>	Date Signed <i>9-21-15</i>
---	--	-------------------------------