



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER -- Governor
RICHARD M. ARMSTRONG -- Director

TAMARA PRISOCK -- ADMINISTRATOR
DIVISION OF LICENSING & CERTIFICATION
DEBRA RANSOM, R.N., R.H.I.T., Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, ID 83720-0009
PHONE 208-334-6626
FAX 208-364-1888

November 02, 2015

Viorel Boeru, Administrator
Advanced Assisted Living
601 West Blaine Avenue
Nampa ID 83651

License #: RC-943

Dear Mr. Boeru:

On September 25, 2015, an on-site follow up Fire Life Safety Survey was conducted at Advanced Assisted Living. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level:

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted plan of correction and evidence of resolution.

Should you have questions, please contact Sam Burbank, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626, option 3.

Sincerely,

Sam Burbank
Health Facility Surveyor
Facility Fire Safety & Construction Program

SB/lj



C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

IDAHO DEPARTMENT OF
HEALTH & WELFARE

DEBBY RANSOM, R.N., R.H.I.T. – Chief
BUREAU OF FACILITY STANDARDS
3232 Ecker Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

September 25, 2015

Viorel Boeru, Administrator
Advanced Assisted Living
601 West Blaine Avenue
Nampa ID 83651

Dear Mr. Boeru:

On September 25, an on-site follow up survey was conducted at Advanced Assisted Living. As a result of the survey, non-core issue deficiencies were re-cited.

Please ensure the facility is continually monitoring its compliance with state rules, as further repeat punches identified during future surveys could result in enforcement actions including:

- a. Issuance of a provisional license
- b. Limitations of admissions to the facility
- c. Hiring a consultant who submits periodic reports to the Licensing and Certification
- d. Civil monetary penalties

As explained during the exit conference, the completed punch list form and accompanying proof of resolution (e.g., receipts, photographs, policy updates, etc.) needs to be submitted to our office no later than **October 26, 2015**.

Should you have any questions, or if we may be of assistance, please call our office at (208) 334-6626.

Sincerely,

Mark P. Grimes
Supervisor
Facility Fire Safety & Construction Program

MPG/lj
Enclosure

Punch Items

Survey Date: 09/25/2015

16.03.22.161.01. Policy on Smoking

The facility must develop written rules governing smoking. These rules must be made known to all facility personnel, residents, and the visiting public.

Smoking being conducted in Laundry room - Repeat -

16.03.22.410.02. Fire Drills.

All personnel and residents must participate in a minimum of one (1) fire drill per shift per quarter. Fire drills must be unannounced.

No Fire drills conducted since 5/28/15; (4) residents and staff interviewed.

16.03.22.405.05. Structure, Maintenance, Equipment to Assure Safety.

The facility must be structurally sound, maintained, and equipped to assure the safety of residents, personnel, and the public including:

Water temperature registers @ 124 degrees - Repeat -

