



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER - Governor
RICHARD M. ARMSTRONG - Director

TAMARA PRISOCK-- ADMINISTRATOR
DIVISION OF LICENSING & CERTIFICATION
DEBRA RANSOM, R.N., R.H.I.T., Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, ID 83720-0009
PHONE 208-334-6626
FAX 208-364-1888

January 6, 2016

April Busby, Administrator
Copper Summit
2424 Birdie Thompson Drive
Pocatello ID 83201

License #: RC-1050

Dear Ms. Busby:

On December 9, 2015, a Fire Life Safety Survey was conducted at Copper Summit. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level:

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Nate Elkins, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626, option 3.

Sincerely,

Nate Elkins
Health Facility Surveyor
Facility Fire Safety & Construction Program

NE/lj



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER - Governor
RICHARD M. ARMSTRONG - Director

TAMARA PRISOCK - ADMINISTRATOR
DIVISION OF LICENSING & CERTIFICATION
DEBRA RANSOM, R.N., R.H.I.T., Chief
BUREAU OF FACILITY STANDARDS
3232 Eder Street
P.O. Box 83720
Boise, ID 83720-0009
PHONE 208-334-6626
FAX 208-364-1888

December 16, 2015

April Busby, Administrator
Copper Summit Assisted Living
2424 Birdie Thompson Drive
Pocatello ID 83201

Dear Ms. Busby:

On December 9, 2015, a Fire Life Safety Survey was conducted at Copper Summit Assisted Living. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by January 11, 2015.

Should you have any questions about our visit, please contact me at (208) 334-6626, option 3.

Sincerely,

MARK P. GRIMES, Supervisor
Facility Fire Safety & Construction Program

MPG/lj
Enclosure

NON-CORE ISSUES

Facility	License #	Physical Address	Phone Number
Copper Summit Assisted Living	RC-1050	2424 Birdie Thompson Drive	208-233-1914
Administrator	City	Zip Code	Survey Date
April Busby	Pocatello	83201	12/9/2015
Survey Team Leader	Survey Type		Response Due
Elkins, Nate	Fire Life Safety and Sanitation Licensure		
Administrator Signature	Date Signed		

Item #	Rule	Description
1	16.03.22.405.07. Exit Door Locks.	All exit doors are double action locks. All locks on exit doors are to be single action.

