



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

TAMARA PRISOCK – ADMINISTRATOR
DIVISION OF LICENSING & CERTIFICATION
DEBRA RANSOM, R.N., R.H.I.T., Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, ID 83720-0009
PHONE 208-334-6626
FAX 208-364-1888

April 6, 2016

Steve Silberberger, Administrator
Seven Oaks Community Homes-- Tybalt
3940 West 5th Avenue #C
Post Falls, ID 83854

RE: Seven Oaks Community Homes - Tybalt, Provider #13G023

Dear Mr. Silberberger:

This is to advise you of the findings of the Medicaid/Licensure Fire Life Safety Survey, which was concluded at Seven Oaks Community Homes-- Tybalt, on March 28, 2016.

Enclosed is your copy of a Statement of Deficiencies/Plan of Correction, form CMS-2567, which states that no Medicaid deficiencies were noted at the time of the survey. Also, enclosed is a similar form stating that no State licensure deficiencies were noted at the time of the survey.

Thank you for the courtesies extended to our staff during our visit. If you have any questions, please call our office at (208) 334-6626, option 3.

Sincerely,

MARK P. GRIMES
Supervisor
Facility Fire Safety and Construction Program

MPG/lj

Enclosure

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

Printed: 04/04/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13G023	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - ENTIRE STRUCTURE B. WING _____	(X3) DATE SURVEY COMPLETED 03/28/2016
NAME OF PROVIDER OR SUPPLIER SEVEN OAKS COMMUNITY HOMES - TYBALT		STREET ADDRESS, CITY, STATE, ZIP CODE 669 NORTH TYBALT POST FALLS, ID 83854		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>The facility is a single story residential type building with Type V (000) construction. It was built in May of 2004. It is fully sprinklered with quick response heads. It has a complete fire alarm/smoke detection system. Currently it is licensed for six ICF/ID beds</p> <p>The facility was found to be in substantial compliance with applicable life safety requirements during the annual Fire/Life Safety survey conducted on March 28, 2016. The facility was surveyed under the LIFE SAFETY CODE, 2000 Edition, Chapter 32 New Residential Evacuation Capability in accordance with 42 CFR 483.470 (j).</p> <p>This survey was conducted by:</p> <p>Sam Burbank Health Facility Surveyor Fire Life Safety and Construction</p>	K 000		
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE		TITLE		(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13G023	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - ENTIRE STRUCTURE B. WING _____	(X3) DATE SURVEY COMPLETED 03/28/2016
NAME OF PROVIDER OR SUPPLIER SEVEN OAKS COMMUNITY HOMES - TYBALT		STREET ADDRESS, CITY, STATE, ZIP CODE 669 NORTH TYBALT POST FALLS, ID 83854		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 000	<p>16.03.11 Initial Comments</p> <p>The facility is a single story residential type building with Type V (000) construction. It was built in May of 2004. It is fully sprinklered with quick response heads. It has a complete fire alarm/smoke detection system. Currently it is licensed for six ICF/ID beds</p> <p>The facility was found to be in substantial compliance with applicable life safety requirements during the annual Fire/Life Safety survey conducted on March 28, 2016. The facility was surveyed under the LIFE SAFETY CODE, 2000 Edition, Chapter 32 New Residential Evacuation Capability in accordance with 42 CFR 483.470 (j) and IDAPA 16.03.11 Intermediate Care Facilities for People with Intellectual Disabilities (ICFs/ID).</p> <p>This survey was conducted by:</p> <p>Sam Burbank Health Facility Surveyor Fire Life Safety and Construction</p>	M 000		

Idaho form
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE _____ TITLE _____ (X6) DATE _____