

Long Term Care Facilities:

Common Deficiency Identified: K054

Smoke detector testing; in addition to annual function testing, sensitivity testing is also required, electronic or written records must be maintained. Please ensure your fire alarm contractor is conducting sensitivity testing and providing you with a record or report. This is also known as calibration testing. For more information please see NFPA 72, 1999 Edition, Section 7-3.2.1

