

Goodman Company Re-announces Recall of Air Conditioning/Heat Pump Units

These units are subject to recall due to the potential hazard of the power cord overheating and causing a fire.

For more information please contact Mark Grimes, Supervisor, Facility Fire Safety and Construction, (208) 334-6626.

For more information regarding Amana-brand units, contact Goodman at (800) 366-0339 between 8 a.m. and 5 p.m. CT Monday through Friday.

For Comfort-Aire and Century-brand units call (877) 442-4482 between 8 a.m. and 5 p.m. ET Monday through Friday; or visit www.regcen.com/ptaccord for all products.