

Citation Frequency Report

Selection Criteria

Begin Year: 2011

End Year: 2011

Display Options: Display all results

Provider and Supplier Type(s): Intermediate Care Facility-Mentally Retarded

State: Idaho

Survey Focus: Life Safety

Year Type: Calendar Year

Year: 2011

Month: Full Year

Totals represent the # of providers and surveys that meet the selection criteria specified above.			Idaho Active Providers= 67	Total Number of Surveys= 67	
Tag #	Tag Description	# Citations	% Providers Cited	% Surveys Cited	Rank
K 051	Fire Alarm System	13	19.40%	19.40%	1
K 046	Emergency Lighting	11	16.40%	16.40%	2
K 154	Automatic Sprinkler System	5	7.50%	7.50%	3
K 155	Fire Alarm System Outage Requirements	5	7.50%	7.50%	3
K 056	Automatic Sprinkler System	4	6.00%	6.00%	4
K 018	Corridor Doors	3	1.50%	4.50%	5
K 147	Electrical Wiring And Equipment	3	4.50%	4.50%	5
K 152	Evacuation Drills	3	4.50%	4.50%	5
K 130	Other	3	4.50%	4.50%	5
K 053	Automatic Smoke Detection System	2	3.00%	3.00%	6
K 029	Hazardous Areas - Separation	2	3.00%	3.00%	6
K 149	Noncombustible Ashtrays	2	3.00%	3.00%	6
K 122	Closet Doors	1	1.50%	1.50%	7
K 011	Common Wall	1	1.50%	1.50%	7
K 017	Corridor Walls	1	1.50%	1.50%	7
K 021	Doors In Fire And Smoke Partitions	1	1.50%	1.50%	7

Tag #	Tag Description	# Citations	% Providers Cited	% Surveys Cited	Rank
K 141	No Smoking Signs Where Oxygen Used	1	1.50%	1.50%	7
K 043	Patient Room Locks	1	1.50%	1.50%	7
K 025	Smoke Partition Construction	1	1.50%	1.50%	7
K 148	Smoking	1	1.50%	1.50%	7
K 066	Smoking Regulations	1	1.50%	1.50%	7
K 070	Space Heaters	1	1.50%	1.50%	7

Standard and Complaint Surveys Combined

Titles are the "main" heading and may not reflect "actual" citation.