

# Citation Frequency Report

## Selection Criteria

**Begin Year:** 2014

**End Year:** 2014

**Display Options:** Display all results

**Provider and Supplier** Intermediate Care Facility-Individuals with Intellectual Disabilities

**Type(s):**  
**State:** Idaho

**Survey Focus:** Life Safety Code

**Year Type:** Calendar Year      **Year:** 2014      **Month:** Full Year

Totals represent the # of providers and surveys that meet the selection criteria specified above.					Idaho Active Providers = <b>69</b>	Total Number of Surveys = <b>60</b>
Tag #	Tag Description	# Citations	% Providers Cited	% Surveys Cited	Rank	
K 152	Evacuation Drills	6	8.7%	10.3%	<b>1</b>	
K 150	Furnishing and Decorations	6	8.7%	10.3%	<b>1</b>	
K 056	Automatic Sprinkler System	4	5.8%	6.9%	<b>3</b>	
K 029	Hazardous Areas - Separation	4	5.8%	6.9%	<b>3</b>	
K 018	Corridor Doors	3	4.3%	5.2%	<b>5</b>	
K 046	Emergency Lighting	3	4.3%	5.2%	<b>5</b>	
K 053	Automatic Smoke Detection System	2	2.9%	3.4%	<b>7</b>	
K 051	Fire Alarm System	2	2.9%	3.4%	<b>7</b>	
K 050	Fire Drills	2	2.9%	3.4%	<b>7</b>	
K 011	Common Wall	1	1.4%	1.7%	<b>10</b>	
K 144	Generatrs Inspected/Tested	1	1.4%	1.7%	<b>10</b>	
K 130	Other	1	1.4%	1.7%	<b>10</b>	
K 120	Sleeping Room Egress	1	1.4%	1.7%	<b>10</b>	
K 052	Testing of Fire Alarm	1	1.4%	1.7%	<b>10</b>	