

Citation Frequency Report

Selection Criteria

Begin Year: **2013**

End Year: **2013**

Display Options: **Display all results**

Tag Description : This is a main heading for a tag, however, the heading may not be reflective of the specific aspect of the deficient practice cited.

Provider and Supplier Type(s): **Intermediate Care Facility-Individual with Intellectual Disabilities**

State: **Idaho**

Survey Focus: **Life Safety**

Year Type: **Calendar Year** Year: **2013** Month: **Full Year**

Idaho Active Providers = **67**

Total Number of Surveys = **65**

Totals represent the # of providers and surveys that meet the selection criteria specified above.

Tag #	Tag Description	# Citations	% Providers Cited	% Surveys Cited	Rank
K 152	Evacuation Drills	9	13.4%	13.8%	1
K 056	Automatic Sprinkler System	6	9.0%	9.2%	2
K 046	Emergency Lighting	6	9.0%	9.2%	
K 011	Common Wall	2	3.0%	3.1%	4
K 154	Automatic Sprinkler System	1	1.5%	1.5%	
K 147	Electrical Wiring And Equipment	1	1.5%	1.5%	
K 051	Fire Alarm System	1	1.5%	1.5%	
K 155	Fire Alarm System Outage Requirements	1	1.5%	1.5%	5
K 043	Patient Room Locks	1	1.5%	1.5%	
K 025	Smoke Barrier Construction	1	1.5%	1.5%	

The data in these reports, including provider and supplier counts and percentages, are valid for the subset of providers or suppliers for which there are survey records in CASPER.

Source: CASPER (02/03/2014)