

Bureau of Facility Standards
ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 1 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

FED - K0000 - INITIAL COMMENTS

Title INITIAL COMMENTS

CFR

Type Memo Tag

Regulation Definition

Interpretive Guideline

FED - K0012 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Buildings two or more stories in height and of Type II(000), III (200), or V (000) construction are equipped throughout with a supervised approved automatic sprinkler system in accordance with section 9.7. 20.1.6.3, 21.1.6.3

FED - K0014 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Interior finish on walls and ceilings of exits, enclosed corridors, and exit access furnishing are Class A or B (offices Class A, B, or C). 38.3.3.2, 39.3.3.2

Bureau of Facility Standards

ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 2 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

FED - K0017 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Corridors used as access to exits are separated from use areas by partitions with a fire resistance rating of at least one hour. Fire resistance rating is not required if building fully sprinklered. Doors have at least one 20 minute fire protection rating and are equipped with a positive latch and closing device. Vision panels, if provided, in partitions or doors therein do not exceed 20 inches and install at or below half the distance from the floor to the room ceiling. 20.3.6.2, 38.3.6.1

Interpretive Guideline

FED - K0020 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Vertical openings such as stairways, elevator shaftways, escalators, and building service shaftways are enclosed in accordance with section 8.2.5. 8.2.5.2, 38.3.1, 39.3.1

Interpretive Guideline

Bureau of Facility Standards

ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 3 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

FED - K0021 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Any door with a required fire protection rating, such as stairways, exit passageways, horizontal exits, smoke barriers, or hazardous area enclosures, if held open, is arranged to close automatically by the actuation of the manual fire alarm system and either smoke detectors arranged to detect smoke on either side of the opening or a complete automatic sprinkler system.
20.2.2.3, 21.2.2.3

Interpretive Guideline

FED - K0029 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Hazardous areas separated from other parts of the building by fire barriers have at least one hour fire resistance rating or such areas are enclosed with partitions and doors and the area is provided with an automatic sprinkler system. High hazard areas are provided with both fire barriers and sprinkler systems 38.3.2, 39.3.2

Interpretive Guideline

Bureau of Facility Standards
ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 4 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

FED - K0031 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Laboratories employing quantities of flammable, combustible, or hazardous materials that are considered a severe hazard are protected in accordance with NFPA 99. (Laboratories that are not considered to be a severe hazard meet the provisions of K29.) Laboratories in health care occupancies and medical and dental offices are in accordance with NFPA 99, Standard for Health Care Facilities and NFPA101. Ventilating systems comply with NFPA 101. 20.3.2.1, 21.3.2.1, 8.4.4, 9.2.4

Interpretive Guideline

FED - K0032 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

At least two exits, located remote from each other, are provided for each floor or fire section of the building. 20.2.4.1, 21.2.4.1, 7.5.1.4

Interpretive Guideline

FED - K0036 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

**Bureau of Facility Standards
ASPEN: Regulation Set (RS)**

Printed 12/08/2009

Page 5 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

Regulation Definition

Interpretive Guideline

Travel distance between any room door required as exit access and an exit does not exceed 100 ft. The travel distance between any point in a room and an exit does not exceed 150 ft. 20.2.6.2, 21.2.6.2

FED - K0037 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Dead-end corridors do not exceed 50 ft. 39.2.5.1, 39.2.5.2, 39.2.5.3

FED - K0039 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Corridors for exit access are at least 44 inches wide. 20.2.3.2, 21.2.3.2

FED - K0040 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Bureau of Facility Standards

ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 6 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

Regulation Definition

Interpretive Guideline

Exit and exit access doors are at least 34 inches wide.

20.2.3.3, 21.2.3.3

FED - K0042 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 426.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Rooms or suites of rooms of more than 2,500 sq. ft. have at least two exit access doors located remote from each other.

20.2.4.2, 21.2.4.2

FED - K0043 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Doors of patient treatment, diagnostic, or recovery rooms are arranged to provide a clear width of not less than 32 inches.

Exception: existing 34 inch doors. 20.2.3.3, 21.2.3.3

Bureau of Facility Standards
ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 7 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

FED - K0046 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Emergency illumination is provided in accordance with section 7.9. 20.2.9.1, 21.2.9.1

FED - K0047 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Exits and ways of travel thereto are marked in accordance with section 7.10. 20.2.10, 21.2.10

FED - K0048 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

There is a written plan for the protection of all patients and for their evacuation in the event of an emergency. 20.7.1.1, 21.7.1.1

Bureau of Facility Standards
ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 8 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

FED - K0050 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Fire drills are held at unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. 20.7.1.2, 21.7.1.2

Interpretive Guideline

FED - K0051 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

A manual fire alarm system, not a pre-signal type, is provided to automatically warn the building occupants. Fire alarm system has initiation notification and control function. The fire alarm system is arranged to automatically transmit an alarm to summon the fire department. 20.3.4.1, 21.3.4.1

Interpretive Guideline

FED - K0064 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Bureau of Facility Standards
ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 9 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

Regulation Definition

Interpretive Guideline

Portable fire extinguishers are provided. 20.3.5.2, 21.3.5.2

FED - K0066 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Smoking regulations are adopted, and include the posting of "NO SMOKING" signs or signs with the international symbol for no smoking in any room, ward, or compartment where flammable liquids, combustible gases or oxygen are used or stored, and in any other hazardous location. 20.7.4, 21.7.4

FED - K0067 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Heating, ventilating, and air-conditioning comply with the manufacturer's specifications and section 9.2. 20.5.2.1, 21.5.2.1

Bureau of Facility Standards
ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 10 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

FED - K0070 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Portable space heating devices are prohibited except in non-sleeping staff and employee areas where the heating elements of such devices do not exceed 212 degrees F (100 degrees C). 20.7.8, 21.7.8

Interpretive Guideline

FED - K0071 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Rubbish chutes, incinerators, and laundry chutes comply with section 7.5. 20.5.4, 21.5.4

Interpretive Guideline

FED - K0072 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Draperies, curtains and other loosely hanging fabrics and films serving as furnishing, except curtains at showers, are in

Interpretive Guideline

Bureau of Facility Standards
ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 11 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

accordance with NFPA 701. 20.7.5.1, 21.7.5.1

FED - K0073 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Newly introduced upholstered furniture is in accordance with NFPA 260, 261 unless the building is fully sprinklered.
20.7.5.2, 21.7.5.2

Newly introduced mattresses meet NFPA 267. 20.7.5.3,
21.7.5.3

FED - K0074 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Combustible decorations are flame retardant. 20.7.5.4,
21.7.5.4

FED - K0075 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Bureau of Facility Standards

ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 12 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

Regulation Definition

Solid linen or trash collection receptacles shall not exceed 32 gallons (121L) in capacity. The average density of container capacity in a room or space shall not exceed 0.5 gal/ft² (20.4L/m²). A capacity of 32 gal (121L) shall not be exceeded with any 64 ft² (5.9m²) area.

Mobile soiled linen or trash collection receptacles with capacity greater than 32 gallons (121L) shall be located in a room protected as a hazardous area when not attended.

20.7.5.3, 21.7.5.5

Interpretive Guideline

FED - K0076 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Medical gas storage and administration areas are protected in accordance with NFPA 99, Standards for Health Care Facilities, and NFPA 101.

(a) Oxygen storage locations of greater than 3,000 cu. ft. are enclosed by a one hour separation.

(b) Locations for supply systems of greater than 3,000 cu. ft. are vented to the outside.

4.3.1.1.2, 20.3.2.4, 21.3.2.4

Interpretive Guideline

**Bureau of Facility Standards
ASPEN: Regulation Set (RS)**

Printed 12/08/2009

Page 13 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

FED - K0077 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Piped in medical gas systems comply with NFPA 99.

FED - K0078 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Anesthetizing locations are protected in accordance with NFPA 99, Standard for Health Care Facilities and NFPA 101.

(a) Shutoff valves are located outside each anesthetizing location and arranged so that shutting off one room or location will not affect others.

(b) Relative humidity is maintained equal to or greater than 35%.

NFPA 99, 4.3.1.2.3(n) and 5.4.1.1, 20.3.2.2, 21.3.3.2

Bureau of Facility Standards
ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 14 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

FED - K0105 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Where general anesthesia or life support equipment is used, an emergency power system is provided in accordance with NFPA 99. 20.2.9.2, 21.2.9.2

Interpretive Guideline

FED - K0106 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

The ASC with life support equipment has a Type I Essential Electrical System powered by a generator with a transfer switch and separate power supply. The EES is in accordance with NFPA 99. 3.4.2.2, 3.4.2.1.4 Required emergency generator is tested and maintained in accordance with NFPA 110 Standard for Emergency and Standby Power Supplies.

Interpretive Guideline

FED - K0112 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Bureau of Facility Standards

ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 15 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

Regulation Definition

At least 50 percent of the required exit capacity from upper floors discharges directly to the exterior of the building in accordance with section 7.7. 38.2.7, 39.2.7, 21.1.6.1, 20.1.6.1

Interpretive Guideline

FED - K0113 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Designated aisles, corridors, passageways, and exitways are provided with illumination in accordance with section 7.8. 20.2.8, 21.2.8

Interpretive Guideline

FED - K0114 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Ambulatory health care occupancies are separated from other tenants and occupancies by fire barriers with at least a 1 hour fire resistance rating. Doors in such barriers are solid bonded core wood of 1¾ inches or equivalent and are equipped with a positive latch and closing device. Vision panels, if provided in fire barriers or doors, are fixed fire window assemblies in accordance with 8.2.3.2.2.

Interpretive Guideline

Bureau of Facility Standards

ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 16 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

FED - K0115 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Ambulatory health care facilities are divided into at least two smoke compartments with smoke barriers having at least 1 hour fire resistance rating. Doors in smoke barriers are equipped with positive latcher. Doors are constructed of not less than 1¾ inch thick solid bonded core wood or equivalent. Vision panels are provided and are of fixed wire glass limited to 1,296 sq. inch per panel. 20.3.7.1, 20.3.7.2, 20.3.7.3, 21.3.7.1, 21.3.7.2, 21.3.7.3

Interpretive Guideline

FED - K0116 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Buildings over 75 ft. in height housing ambulatory health care facilities are provided with a complete approved automatic sprinkler system in accordance with 11.8.

Interpretive Guideline

FED - K0117 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

**Bureau of Facility Standards
ASPEN: Regulation Set (RS)**

Printed 12/08/2009

Page 17 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

Regulation Definition

Utilities shall comply with section 9.1 Electrical Wiring and Equipment and shall be in accordance with NFPA 70 National Electrical Code. 20.5.1, 21.5.1, 9.1, See also K-147

Interpretive Guideline

FED - K0118 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Elevators, dumbwaiters, and vertical conveyors comply with section 9.4. 20.5.3, 21.5.3

Interpretive Guideline

FED - K0130 - MISCELLANEOUS

Title MISCELLANEOUS

CFR NFPA 101

Type Standard

Regulation Definition

OTHER LSC DEFICIENCY NOT ON 2786

Interpretive Guideline

FED - K0131 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

**Bureau of Facility Standards
ASPEN: Regulation Set (RS)**

Printed 12/08/2009

Page 18 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

Regulation Definition

Interpretive Guideline

Emergency procedures are established for controlling chemical spills in accordance with NFPA 99. 10.2.1.3.2

FED - K0132 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Continuing safety education and supervision are provided, incidents are reviewed monthly, and procedures are reviewed annually in accordance with NFPA 99. 10.2.1.4.2

FED - K0133 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Fume hoods are in accordance with NFPA 99. 5.4.3, 5.6.2

FED - K0134 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Bureau of Facility Standards
ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 19 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

Regulation Definition

Where the eyes or body of any person can be exposed to injurious corrosive materials, suitable fixed facilities for quick drenching or flushing of the eyes and body are provided within the work area for immediate emergency use. Fixed eye baths are designed and installed to avoid injurious water pressure in accordance with NFPA 99. 10.6

Interpretive Guideline

FED - K0135 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Flammable and combustible liquids are used from and stored in approved containers in accordance with NFPA 30, Flammable and Combustible Liquids Code, and NFPA 45, Standard on Fire Protection for Laboratories Using Chemicals. Storage cabinets for flammable and combustible liquids are constructed in accordance with NFPA 30, Flammable and Combustible Liquids Code, NFPA 99. 4.3, 10.7.2.1

Interpretive Guideline

FED - K0136 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Procedures for laboratory emergencies are developed. Such procedures include alarm actuation, evacuation, and equipment shutdown procedures, and provisions for control of

Interpretive Guideline

Bureau of Facility Standards

ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 20 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

emergencies that could occur in the laboratory, including specific detailed plans for control operations by an emergency control group within the organization or a public fire department in accordance with NFPA 99 and NFPA 101.
10.2.1.3.1, 20.3.2.1, 21.3.2.1

FED - K0140 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Master alarm panels are in two separate locations and have audible and visible signals. There are high/low alarms for +/- 20% operating pressure. This section is in accordance with NFPA 99. 4.3.1.2.2

Interpretive Guideline

FED - K0141 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Non-smoking and no smoking signs in areas where oxygen is used or stored are in accordance with NFPA 99. 8.6.4.2

Interpretive Guideline

FED - K0142 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Bureau of Facility Standards

ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 21 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

Regulation Definition

All occupancies containing hyperbaric facilities comply with NFPA 99, Standard for Health Care Facilities, Chapter 19.

Interpretive Guideline

FED - K0143 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Transferring of oxygen is:

(a) separated from any portion of a facility wherein patients are housed, examined, or treated by a separation of a fire barrier of one hour fire-resistive construction;

(b) in an area that is mechanically ventilated, sprinklered, and has ceramic or concrete flooring; and

(c) in an area posted with signs indicating that transferring is occurring, and that smoking in the immediate area is not permitted in accordance with NFPA 99 and the Compressed Gas Association. 8.6.2.5.2

Interpretive Guideline

FED - K0144 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Bureau of Facility Standards
ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 22 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

Regulation Definition

Generators are inspected weekly and exercised under load for 30 minutes per month in accordance with NFPA 99. 3.4.4.1, NFPA 110, 8.4.2

Interpretive Guideline

FED - K0145 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

The Type I EES is divided into the critical branch, life safety branch and the emergency system in accordance with NFPA 99. 3.4.2.2.2

Interpretive Guideline

FED - K0146 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

The ASC with no life support equipment has an alternate source of power separate and independent from the normal source that will be effective for minimum of 1½ hour after loss of normal source in accordance with NFPA 99. 3.6.3.1.1

Interpretive Guideline

**Bureau of Facility Standards
ASPEN: Regulation Set (RS)**

Printed 12/08/2009

Page 23 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

FED - K0147 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

Electrical wiring and equipment are in accordance with NFPA 70, National Electrical Code 9.1.2, 20.5.1

FED - K0211 - LIFE SAFETY CODE STANDARD

Title LIFE SAFETY CODE STANDARD

CFR 416.44(b)(1)

Type Standard

Regulation Definition

Interpretive Guideline

- o Where Alcohol Based Hand Rub (ABHR) dispensers are installed in a corridor, the corridor is at least 6 feet wide
 - o The maximum individual fluid dispenser capacity shall be 1.2 liters (2 liters in suites of rooms)
 - o The dispensers have a minimum spacing of 4 ft from each other
 - o Not more than 10 gallons are used in a single smoke compartment outside a storage cabinet.
 - o Dispensers are not installed over or adjacent to an ignition source.
 - o If the floor is carpeted, the building is fully sprinklered.
- 19.3.2.7, CFR 403.744, 418.100, 460.72, 482.41, 483.70, 483.623, 485.623

Bureau of Facility Standards
ASPEN: Regulation Set (RS)

Printed 12/08/2009

Page 24 of 24

Aspen Federal Regulation Set: K 01.05 LSC 2000 ASC and ESRD Existing

FED - K9999 - FINAL OBSERVATIONS

Title FINAL OBSERVATIONS

CFR

Type Memo Tag

Regulation Definition

Interpretive Guideline