

Citation Frequency Report

Selection Criteria

Begin Year: **2013**

End Year: **2013**

Display Options: **Display all results**

Provider and Supplier: **Dually Certified SNF/NFs - Medicare and Medicaid, Distinct Part SNF/NFs - Medicare and Medicaid, Skilled Nursing Facilities (SNFs) - Medicare Only, Nursing Facilities - Medicaid**

Type(s): **Only**

State: **Idaho**

Survey Focus: **Life Safety**

Year Type: **Calendar Year** Year: **2013** Month: **Full Year**

Idaho Active Providers = **78**

Total Number of Surveys = **72**

Totals represent the # of providers and surveys that meet the selection criteria specified above.

Tag #	Tag Description	# Citations	% Providers Cited	% Surveys Cited	Rank
K 038	Exit Access	26	33.3%	36.1%	1
K 147	Electrical Wiring and Equipment	25	32.1%	34.7%	2
K 062	Sprinkler System Maintenance	22	28.2%	30.6%	3
K 144	Generatrs Inspected/Tested	17	21.8%	23.6%	4
K 029	Hazardous Areas - Separation	17	21.8%	23.6%	4
K 069	Cooking Equipment	14	17.9%	19.4%	6
K 056	Automatic Sprinkler System	13	16.7%	18.1%	7
K 018	Corridor Doors	12	15.4%	16.7%	8
K 050	Fire Drills	11	14.1%	15.3%	9
K 025	Smoke Barrier Construction	10	12.8%	13.9%	10

Tag Description : This is a main heading for a tag, however, the heading may not be reflective of the specific aspect of the deficient practice cited.

The data in these reports, including provider and supplier counts and percentages, are valid for the subset of providers or suppliers for which there are survey records in CASPER.

Source: CASPER (02/03/2014)