



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

May 8, 2013

Stephanie Arceneaux, Administrator
Valley View Investors, LLC - The Bridge at Valley
1130 North Allumbaugh Street
Boise, ID 83704

License #: RC-250

Dear Ms. Arceneaux:

On March 29, 2013, a Fire Life Safety Survey was conducted at Valley View Investors, LLC - The Bridge at Valley View. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level(s):

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact me at (208) 334-6626.

Sincerely,

Taylor Barkley
Health Facility Surveyor
Facility Fire Safety & Construction Program

TB/nm

c: Mark Grimes, Supervisor, Facility Fire Safety & Construction Program



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER, Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

April 4, 2013

Stephanie Arceneaux, Administrator
Valley View Investors, LLC - The Bridge at Valley
1130 North Allumbaugh Street
Boise, ID 83704

Dear Ms. Arceneaux:

On March 29, 2013, a Fire Life Safety Survey was conducted at Valley View Investors, LLC - The Bridge at Valley View. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by April 28, 2013.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

MARK P. GRIMES, Supervisor
Facility Fire Safety & Construction Program

MPG/nm
Enclosure

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13R250	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 - ENTIRE BUILDING B. WING _____	(X3) DATE SURVEY COMPLETED 03/29/2013
NAME OF PROVIDER OR SUPPLIER VALLEY VIEW INVESTORS, LLC - THE BRIDGE		STREET ADDRESS, CITY, STATE, ZIP CODE 1130 NORTH ALLUMBAUGH STREET BOISE, ID 83704		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
R 000	<p>Initial Comments</p> <p>The facility was found to be in substantial compliance with the life safety code requirements of the Rules for Residential or Assisted Living Facilities in Idaho. No core deficiencies were cited during the standard life safety code survey conducted on March 29, 2013.</p> <p>The surveyor conducting the survey was:</p> <p>Taylor Barkley Health Facility Surveyor Facility Fire Safety & Construction</p>	R 000		

Bureau of Facility Standards

TITLE

(X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

