



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

October 26, 2012

Angela Martin, Administrator
Carefix-- Safe Haven Homes of Shelley
183 East Oak
Shelley, Idaho 83274

License #: RC-928

Dear Ms. Martin:

On September 14, 2012, a Fire Life Safety Survey was conducted at Carefix-- Safe Haven Homes of Shelley. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level:

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Taylor Barkley , Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626.

Sincerely,

TAYLOR BARKLEY
Health Facility Surveyor
Facility Fire Safety & Construction Program

TB/lj

c: Mark Grimes, Supervisor, Facility Fire Safety & Construction Program



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER, Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

September 20, 2012

Angela Martin, Administrator
Carefix--Safe Haven Homes of Shelley
183 East Oak
Shelley, Idaho 83274

Dear Ms. Martin:

On September 14, 2012, a Fire Life Safety Survey was conducted at Safe Haven Homes of Shelley. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by October 14, 2012.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

MARK P. GRIMES
Supervisor
Facility Fire Safety & Construction Program

MPG/lj

Enclosure

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13R928	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - ENTIRE BUILDING B. WING _____	(X3) DATE SURVEY COMPLETED 09/14/2012
NAME OF PROVIDER OR SUPPLIER CAREFIX-SAFE HAVEN HOMES OF SHELLEY		STREET ADDRESS, CITY, STATE, ZIP CODE 183 EAST OAK SHELLEY, ID 83274		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
R 000	<p>Initial Comments</p> <p>The facility was found to be in substantial compliance with the life safety code requirements of the Rules for Residential or Assisted Living Facilities in Idaho. No core deficiencies were cited during the standard life safety code survey conducted on September 14, 2012.</p> <p>The surveyor conducting the survey was:</p> <p>Taylor Barkley Health Facility Surveyor Facility Fire Safety & Construction</p>	R 000		

Bureau of Facility Standards

TITLE

(X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

