



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

November 14, 2011

Michelle Anderson, Administrator
No Place Like Home Assisted Living
679 Troy Avenue
Idaho Falls, Idaho 83402

License #: RC-966

Dear Ms. Anderson:

On October 26, 2011, a Fire Life Safety Survey was conducted at No Place Like Home Assisted Living. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level:

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Eric Mundell, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626.

Sincerely,

ERIC MUNDELL
Health Facility Surveyor
Facility Fire Safety & Construction Program

EM/lj

c: Mark Grimes, Supervisor, Facility Fire Safety & Construction Program



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER, Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

November 1, 2011

Michelle Anderson, Administrator
No Place Like Home Assisted Living
679 Troy Avenue
Idaho Falls, Idaho 83402

Dear Ms. Anderson:

On October 26, 2011, a Fire Life Safety Survey was conducted at No Place Like Home Assisted Living. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by November 26, 2011.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

MARK P. GRIMES
Supervisor
Facility Fire Safety & Construction Program

MPG/lj

Enclosure

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13R966	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - ENTIRE BUILDING B. WING _____	(X3) DATE SURVEY COMPLETED 10/26/2011
--------------------------------------------------	-------------------------------------------------------------------------	----------------------------------------------------------------------------------------	-----------------------------------------------------

NAME OF PROVIDER OR SUPPLIER NO PLACE LIKE HOME ASSISTED LIVING	STREET ADDRESS, CITY, STATE, ZIP CODE 679 TROY AVENUE IDAHO FALLS, ID 83402
-------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	------------------------------------------------------------------------------------------------------------------------	---------------	-----------------------------------------------------------------------------------------------------------------	--------------------

R 000	<p>Initial Comments</p> <p>The facility was found to be in substantial compliance with the fire and life safety requirements of IDAPA 16.03.22 Residential Care or Assisted Living Facilities in Idaho. No core deficiencies were cited during the standard fire/life safety survey conducted on October 26, 2011.</p> <p>The surveyor conducting the survey was:</p> <p>Eric Mundell REHS Health Facility Surveyor Facility Fire/Life Safety & Construction Program</p>	R 000		
-------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------	--	--

Bureau of Facility Standards

TITLE

(X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

STATE FORM

6899

Z86221

If continuation sheet 1 of 1

