



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

January 4, 2012

Marlys Bailey, Administrator
The Cottages of Boise
6300 North Roe Street
Boise, Idaho 83714

License #: RC-938

Dear Ms. Bailey:

On December 1, 2011, a Fire Life Safety Survey was conducted at The Cottages of Boise. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level:

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Taylor Barkley, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626.

Sincerely,

TAYLOR BARKLEY
Health Facility Surveyor
Facility Fire Safety & Construction Program

TB/lj

c: Mark Grimes, Supervisor, Facility Fire Safety & Construction Program



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER, Governor
RICHARD M. ARMSTRONG -- Director

OEBBY RANSOM, R.N., R.H.I.T -- Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

December 13, 2011

Marlys Bailey, Administrator
The Cottages of Boise
6300 North Roe Street
Boise, Idaho 83714

Dear Ms. Bailey:

On December 1, 2011, a Fire Life Safety Survey was conducted at The Cottages of Boise. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by December 31, 2011.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

A handwritten signature in black ink, appearing to read "MPG", followed by a long horizontal flourish.

MARK P. GRIMES
Supervisor
Facility Fire Safety & Construction Program

MPG/lj

Enclosure

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13R938	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - 6300 NORTH ROE STREET B. WING _____	(X3) DATE SURVEY COMPLETED 12/01/2011
NAME OF PROVIDER OR SUPPLIER COTTAGE INVESTORS, LLC DBA THE COTTA		STREET ADDRESS, CITY, STATE, ZIP CODE 6300 + 6352 NORTH ROE STREET BOISE, ID 83714		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
R 000	<p>Initial Comments</p> <p>The facility was found to be in substantial compliance with the life safety code requirements of the Rules for Residential or Assisted Living Facilities in Idaho. No core deficiencies were cited during the standard life safety code survey conducted on December 1, 2011.</p> <p>The surveyor conducting the survey was:</p> <p>Taylor Barkley Health Facility Surveyor Facility Fire Safety & Construction</p>	R 000		

Bureau of Facility Standards

TITLE

(X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

