



IDAHO DEPARTMENT OF  
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor  
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T. – Chief  
BUREAU OF FACILITY STANDARDS  
3232 Elder Street  
P.O. Box 83720  
Boise, Idaho 83720-0009  
PHONE: (208) 334-6626  
FAX: (208) 364-1888  
E-mail: [fsb@dhw.idaho.gov](mailto:fsb@dhw.idaho.gov)

July 26, 2013

Terese Sackos, Administrator  
Amber Lane Residence - Amber Lane, Inc.  
1819 West Bannock Street  
Boise, ID 83702

License #: RC-744

Dear Ms. Sackos:

On June 19, 2013, a Fire Life Safety Survey was conducted at Amber Lane Residence - Amber Lane, Inc. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level(s):

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact me at (208) 334-6626.

Sincerely,

TAYLOR BARKLEY  
Health Facility Surveyor  
Facility Fire Safety & Construction Program

TB/nm



IDAHO DEPARTMENT OF  
HEALTH & WELFARE

C.L. "BUTCH" OTTER, Governor  
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief  
BUREAU OF FACILITY STANDARDS  
3232 Elder Street  
P.O. Box 83720  
Boise, Idaho 83720-0009  
PHONE: (208) 334-6626  
FAX: (208) 364-1888  
E-mail: [fsb@dhw.idaho.gov](mailto:fsb@dhw.idaho.gov)

June 27, 2013

Terese Sackos, Administrator  
Amber Lane Residence - Amber Lane, Inc.  
1819 West Bannock Street  
Boise, ID 83702

Dear Ms. Sackos:

On June 19, 2013, a Fire Life Safety Survey was conducted at Amber Lane Residence - Amber Lane, Inc. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by July 19, 2013.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

MARK P. GRIMES, Supervisor  
Facility Fire Safety & Construction Program

MPG/nm  
Enclosure

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>13R744</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: <b>01 - ENTIRE BUILDING</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>06/19/2013</b>
NAME OF PROVIDER OR SUPPLIER  <b>AMBER LANE RESIDENCE - AMBER LANE, INI</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>1819 WEST BANNOCK STREET BOISE, ID 83702</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
R 000	<p>Initial Comments</p> <p>The facility was found to be in substantial compliance with the life safety code requirements of the Rules for Residential or Assisted Living Facilities in Idaho. No core deficiencies were cited during the standard life safety code survey conducted on June 19, 2013.</p> <p>The surveyor conducting the survey was:</p> <p>Taylor Barkley Health Facility Surveyor Facility Fire Safety &amp; Construction</p>	R 000		

Bureau of Facility Standards

TITLE

(X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE



Facility Name Amber Lane Residence	Physical Address 1819 W Bannock St	Phone Number 208-336-5004
Administrator Terese Sackos	City Boise, Id	ZIP Code 83702
Survey Team Leader Taylor Barkley	Survey Type	Survey Date 6-19-13

**NON-CORE ISSUES**

ITEM #	RULE # 16.03.22	DESCRIPTION	DATE RESOLVED	L & C USE
1	410.01	The facility does not have a written Agreement for relocation.	7-25-13	7B
2	415.02 750.03	The last annual fuel fired heating inspection was on May 30, 2012.	6-22-13	7B
3	410.02 750.01	The facility did not conduct one drill per shift per quarter	7-25-13	7B
		Items # 2 and 3 are repeat deficiencies previously cited on May 2, 2012.		

Response Required Date 7-19-13	Signature of Facility Representative <i>Cassia Lindsey</i>	Date Signed 6/19/13
-----------------------------------	---	------------------------