



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

November 10, 2014

Joy Cook, Administrator
Serenity Place Residential Care
1917 17th Avenue
Lewiston, ID 83501

License #: RC-969

Dear Ms. Cook:

On October 22, 2014, a Fire Life Safety Survey was conducted at Serenity Place Residential Care. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level:

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Sam Burbank, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626.

Sincerely,

SAM BURBANK
Health Facility Surveyor
Facility Fire Safety & Construction Program

SB/lj



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER, Governor
RICHARD M. ARMSTRONG -- Director

DEBBY RANSOM, R.N., R.H.I.T -- Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

November 10, 2014

Joy Cook, Administrator
Serenity Place Residential Care
1917 17th Avenue
Lewiston, Idaho 83501

Dear Ms. Cook:

On October 22, 2014, a Fire Life Safety Survey was conducted at Serenity Place Residential Care. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by November 21, 2014.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

MARK P. GRIMES, Supervisor
Facility Fire Safety & Construction Program

MPG/lj
Enclosure

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13R969	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 - ENTIRE BUILDING B. WING _____	(X3) DATE SURVEY COMPLETED 10/22/2014
--	--	--	--

NAME OF PROVIDER OR SUPPLIER SERENITY PLACE RESIDENTIAL CARE	STREET ADDRESS, CITY, STATE, ZIP CODE 1917 17TH AVENUE LEWISTON, ID 83501
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

R 000	<p>Initial Comments</p> <p>The facility was found to be in substantial compliance with the fire and life safety requirements of IDAPA 16.03.22 Residential Care or Assisted Living Facilities in Idaho. No core deficiencies were cited during the standard fire/life safety survey conducted on October 22, 2014.</p> <p>The surveyor conducting the survey was:</p> <p>Sam Burbank Health Facility Surveyor Facility Fire/Life Safety & Construction Program</p>	R 000		
-------	--	-------	--	--

Bureau of Facility Standards LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
---	-------	-----------



Facility Name Serenity Place Residential Living	Physical Address 1917 17TH AVE	Phone Number 208-793-0026
Administrator Joy Cook	City LEWISTON	ZIP Code 83843
Survey Team Leader SAM BURBANK	Survey Type FLS	Survey Date 10/22/14

NON-CORE ISSUES

ITEM	CODE	DESCRIPTION	DATE RECEIVED
1	405.05	RESIDENT ROOM DOORS 115, 108, 107 WOULD NOT CLOSE & LATCH WITHOUT EXCESS EFFORT	10-28-14
		on 10/28/14 windows poors and more the original installing contractors, came to Serenity Place Residential care and took each of the above mentioned poors off hinges and reinstalled to open effortlessly.	
		Plan to prevent future occurrences we will check each door every month after fire drills.	
		<i>Joy Cook</i> 10-28-14	

Response Required Date
11/22/14

Signature of Facility Representative
[Signature]