



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER – Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

January 27, 2015

Carissa Bullets, Administrator
Peak Village
PO Box 1722
Idaho Falls, ID 83403

License #: RC-1051

Dear Ms. Bullets:

On December 9, 2014, a Fire Life Safety Survey was conducted at Peak Village. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level:

- Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.


Should you have questions, please contact Nathan Elkins, Health Facility Surveyor, Facility Fire Safety and Construction Program, at (208) 334-6626.

Sincerely,

A handwritten signature in black ink, appearing to read "Nathan Elkins".

NATHAN ELKINS
Health Facility Surveyor
Facility Fire Safety & Construction Program

NE/lj



IDAHO DEPARTMENT OF
HEALTH & WELFARE

C.L. "BUTCH" OTTER, Governor
RICHARD M. ARMSTRONG – Director

DEBBY RANSOM, R.N., R.H.I.T – Chief
BUREAU OF FACILITY STANDARDS
3232 Elder Street
P.O. Box 83720
Boise, Idaho 83720-0009
PHONE: (208) 334-6626
FAX: (208) 364-1888
E-mail: fsb@dhw.idaho.gov

December 16, 2014

Carissa Bullets, Administrator
Peak Village
PO Box 1722
Idaho Falls, ID 83403

Dear Ms. Bullets:

On December 9, 2014, a Fire Life Safety Survey was conducted at Peak Village. The facility was found to be providing a safe environment for its residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying evidence of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by January 9, 2015.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

MARK P. GRIMES, Supervisor
Facility Fire Safety & Construction Program

MPG/lj
Enclosure

Bureau of Facility Standards

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 13R1051	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 - PEAK VILLAGE B. WING _____	(X3) DATE SURVEY COMPLETED 12/09/2014
NAME OF PROVIDER OR SUPPLIER PEAK VILLAGE		STREET ADDRESS, CITY, STATE, ZIP CODE 1035 CURLEW DRIVE AMMON, ID 83406		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
R 000	<p>Initial Comments</p> <p>The facility was found to be in substantial compliance with the fire and life safety requirements of IDAPA 16.03.22 Residential Care or Assisted Living Facilities in Idaho. No core deficiencies were cited during the standard fire/life safety survey conducted on December 9, 2014.</p> <p>The surveyor conducting the survey was:</p> <p>Nathan Elkins Health Facility Surveyor</p>	R 000		

Bureau of Facility Standards

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE



Facility Name <i>Teton Peak</i>	Physical Address <i>1035 Curlew DR</i>	Phone Number <i>208-529-4088</i>
Administrator <i>Carissa Bullett</i>	City <i>Ammon</i>	ZIP Code <i>83406</i>
Survey Team Leader <i>Nathan Elkins</i>	Survey Type <i>Re certification</i>	Survey Date <i>12/9/14</i>

NON-CORE ISSUES

ITEM #	RULE #	DESCRIPTION	DATE RESOLVED
1	415.02	No Annual records found for fuel fired heating systems (Elkhorn, Diamond, Castle, Borah)	1/9/15 ^{NSC}
2	415.05	No records of Annual Sprinkler System Test/Inspection (Elkhorn, Diamond, Castle, Borah)	12/15/14 ^{NSC}
3	405.07	Delayed egress not installed in accordance with 7.2.46.1	
4	415.01	One (1) inch open penetrations found in ceiling/walls in utility rooms for Elkhorn, Diamond, Castle, Borah	1/9/15 ^{NSC}

Response Required Date

1/9/14

Signature of Facility Representative

Carissa Bullett